LOCAL TECHNICAL AMENDMENT

FLORIDA BUILDING CODE 2010 - RESIDENTIAL

AMEND EXISTING SECTION

P2903.1Water supply system design criteria. The water service and water distribution systems shall be designed and pipe sizes shall be selected such that under conditions of peak demand, the capacities at the point of outlet discharge shall not be less than shown in Table P2903.1. Table P2903.2b shall be permitted to be used to size the water service or water distribution system.

EXCEPTION: For any one, two or three residential family dwellings. When the building owner approves in writing, one bathroom group may be added to the existing hot and cold water system, not to exceed a maximum of eight drainage fixture units for any fixtures added. In no case shall the additional fixtures be connected to existing piping less than ¾" diameter (Hot and/or Cold).

Local Conditions and Need: This amendment allows building owners flexibility when adding one bathroom group to an existing hot and/or cold system.

Fiscal Impact Statement: There is no cost impact associated with this amendment.

Effective Date: Effective date of Florida Building Code 2010 - Residential.

This amendment if implemented would not discriminate against materials, products, or construction techniques of demonstrated capabilities.