

**LOCAL TECHNICAL AMENDMENT**  
**FLORIDA BUILDING CODE 2007 - RESIDENTIAL**

**AMEND EXISTING SECTION**

**SECTION M1411 REFRIGERATION COOLING EQUIPMENT**

**M1411.3 Condensate disposal.**

**Add:**

M1411.3.3 Pipe insulation: All horizontal primary condensate drain within unconditioned areas shall be insulated.

**Local Conditions and Need:** This amendment requires all horizontal primary condensate drain within unconditioned areas to be insulated.

**Fiscal Impact Statement:** Minimal cost impact associated with this amendment.

**Effective Date:** Effective date of Florida Building Code 2007 - Residential.

This amendment if implemented would not discriminate against materials, products, or construction techniques of demonstrated capabilities.